



FuelCell Energy  
World Leader in Ultra-Clean Power

## Carbonate Fuel Cell Application for Synergistic Power Generation and Carbon Dioxide Capture

***Hossein Ghezel-Ayagh, Mohammad Farooque, Dilip Patel,  
Robert Sanderson, James Walzak, Jennifer Hunt***  
**FuelCell Energy, Inc., Danbury, CT 06813**


**2009 Fuel Cell Seminar & Exposition  
November 16-19, 2009  
Palm Springs, California**

reliable, efficient, ultra-clean



*There is a steady growth in electric power generation, while there is a growing concern for climate change as a result of carbon dioxide emissions*

- **Global demand for electric power expected to grow from 16.4 to 27.1 trillion kWh by 2025<sup>1</sup>**
- **66% of the world's electricity was from fossil fuels in 2005<sup>2</sup>**
- **Environmental needs driving ultra-clean power generation solutions**
- **Ability to reduce energy cost and CO<sub>2</sub> dependent on increasing energy efficiency**




U.S. 2006 Data from <http://www.eia.doe.gov/cneaf/electricity/epa/epat1p1.html>

1. Energy Information Administration, "International Energy Outlook 2007, p. 61.  
2. International Energy Agency, Key World Energy Statistics 2007, p. 24.



## CO<sub>2</sub> Transfer Mechanism in Direct FuelCell




**Carbon Dioxide is transferred from cathode to anode via carbonate ions.**



FuelCell Energy  
World Leader in Ultra-Clean Power

# Carbonate Fuel Cell Technology





**FuelCell Energy**  
World Leader in Ultra-Clean Power

## Production Capabilities

- **Production and delivery capabilities meet current demand**
- **State-of-the-art manufacturing in Torrington, CT**
- **70 MW capacity**
- **Production rate of 30 MW/year**
- **Strong supply chain in place**
- **Expansion plan to achieve 150 MW capacity**



**Torrington, CT - Manufacturing Facility**



**Danbury, CT - Headquarters, R&D, Stack Conditioning**



**FuelCell Energy**  
World Leader in Ultra-Clean Power

## Core Product: DFC Cells and Stack Modules

- **FCE manufactures complete Direct FuelCell® cells and stack modules from raw materials and purchased parts in our Torrington, CT manufacturing facility**

**Electrode, Matrix and Bipolar Plate Manufacturing**



**Assembled Cell Package**





**FuelCell Energy**  
World Leader in Ultra-Clean Power

# DFC Stack Assembly



**Stack Assembly Process**



**Assembled Stacks Ready For  
Module Integration**



FuelCell Energy  
World Leader in Ultra-Clean Power

# Building Block Approach to Product Line




Cell Package and Stack




Single-Stack Module




Four-Stack Module




DFC300  
Single 1-Stack Module  
Powerplant



DFC1500MA  
Four 1-Stack Modules  
Powerplant



DFC1500B  
One 4-Stack  
Module Powerplant



DFC3000: Two 4-  
Stack Modules  
Powerplant



**FuelCell Energy**  
World Leader in Ultra-Clean Power

## DFC Power Plants in Operation

***1.2 MW DFC1500 at  
Pepperidge Farm Bakery in  
Bloomfield, CT***




***World's 1st DFC3000 (2.4  
MW) Installation in Korea***



**Megawatt Scale Fuel Cell Technology Available for On-Site Power Generation**




DFC power plant costs are declining while the cost of grid power increases






*1<sup>st</sup> gross margin profitable MW-class units began production in July 2009*

***Captured Cost Reduction  
from 2003-2006***



***Future Cost Reductions to  
Less Than \$2000/kW***






### Why Direct FuelCell for Carbon Capture?



- **By using DFC, it is feasible to separate at least 90% of carbon dioxide from the greenhouse gases (GHG) generated by coal fired power plants.**
- **Unlike other carbon dioxide capture technologies which reduce net electric power, DFC increases the power generated by the existing fossil fueled plants.**
- **DFC systems generate clean water, an important feature where water is scarce.**
- **Pristine clean exhaust gas to the environment.**
  - **Carbonate fuel cells significantly reduce NOx emissions produced by the older plants.**



FuelCell Energy  
World Leader in Ultra-Clean Power

# DFC-Based CO<sub>2</sub> Sequestration System Concept






Fuel cell with 250 cm<sup>2</sup> area were utilized to confirm the carbon dioxide capture of up to 90 percent from simulated flue gas of various coal fueled power plants.




## Fuel Cell Performance on Simulated PC Boiler Flue Gas






### Fuel Cell Performance on Simulated IGCC Exhaust Gas





Ratio of NOx at Cathode Exhaust to NOx at Cathode Inlet





<b>Application</b>	<b>GHG removal from 200MW coal fueled power plant</b>
<b>Effectiveness</b>	<b>&gt;90% of CO<sub>2</sub> removed</b>
<b>Power Output Characteristics</b>	<b>Output Voltage: 13.8 kV (IEEE Standard 519) Power Factor Range: 0.90 Lag to 0.90 Lead at rated output Power Output Phase: 3 Phase, Wye, 4 Wire Frequency: 60 Hz ± 5%</b>
<b>Power Plant Life</b>	<b>25 Years</b>
<b>Availability</b>	<b>92%</b>



# Case Studies: Coal Fueled Power Plant Exhaust Streams

	<b>Pulverized Coal Boiler Steam Cycle Plant [1]</b>	<b>Atmospheric Circulating Fluidized Bed Boiler Steam Cycle Plant [2]</b>	<b>Integrated (coal) Gasification Combined Cycle Power Plant [2]</b>	
			<b>Existing Plant</b>	<b>Commercially Offered Future Plant</b>
<b>Gas Composition (mole %)</b>				
CO <sub>2</sub>	<b>12.06</b>	<b>14.40</b>	<b>7.49</b>	<b>7.85</b>
O <sub>2</sub>	<b>4.47</b>	<b>3.32</b>	<b>11.95</b>	<b>11.76</b>
N <sub>2</sub> + Ar	<b>70.32</b>	<b>74.81</b>	<b>65.73</b>	<b>72.55</b>
H <sub>2</sub> O	<b>13.13</b>	<b>7.45</b>	<b>14.84</b>	<b>7.83</b>
<b>Temperature (deg F)</b>	<b>129</b>	<b>291</b>	<b>280</b>	<b>280</b>
<b>Pressure (psia)</b>	<b>14.7</b>	<b>14.7</b>	<b>14.7</b>	<b>14.7</b>
<b>Flow Rate (lbmole/h)*</b>	<b>69,269</b>	<b>63,032</b>	<b>100,563</b>	<b>115,573</b>

\* Scaled to 200 MW net plant size

[1] E. Parsons (NETL) and W. Shelton (EG&G), "Advanced Fossil Power Systems Comparison Study," Final Report, Dec 2002, Prepared for: National Energy Technology Laboratory (NETL)


[2] "Greenhouse Gas Emissions Control by Oxygen Firing in Circulating Fluidized Bed Boilers: Phase I – A Preliminary Systems Evaluation," Final Report (Volume I), May 2003, Prepared for: National Energy Technology Laboratory, By: Alstom Power, Inc., Windsor, CT



 **DFC system has shown excellent performance in separation of carbon dioxide in the study of various types of coal fueled power plants**


PLANT TYPE	Net Power MW		CO <sub>2</sub> to Environment lbs/MW hr	
	w/o DFC	with DFC	w/o DFC	with DFC
Pulverized Coal (PC) Steam Plant	200	341	1838	108
ACFB Steam Plant	200	353	1997	113
IGCC Plant	200	327	1657	101

  
DFC provides  
additional power

  
> 90% CO<sub>2</sub> separation  
from the greenhouse gas  
(per unit energy produced)




## Percent Increment in Net Power Resulting from CO<sub>2</sub> Capture



 **DFC Based System Compared to State-of-the-Art Amine Scrubbing Technologies**




## Percent Increment in Capital Cost Resulting from CO<sub>2</sub> Capture



**DFC Based System Compared to State-of-the-Art Amine Scrubbing Technologies**




## Percent Increment in Cost-of-Electricity Resulting from CO<sub>2</sub> Capture



**DFC Based System Compared to State-of-the-Art Amine Scrubbing Technologies**



- **Percent increase in cost-of-electricity for a PC plant producing power at 6.4¢/kWh**



➔ **Less than 35% increase in COE is achievable by using the electrochemical separation technology.**



- **Direct FuelCell technology offers a unique and attractive alternative for CO<sub>2</sub> capture.**
- **Results of the fuel cell tests with simulated PC plant flue gas have verified the potential of Direct FuelCell technology for >90% carbon dioxide separation.**
- **Conceptual designs of DFC based systems, focusing on GHG mitigation from coal fired plants, were developed.**
- **Economic analysis has indicated that DFC based systems offer cost-effective solutions for combined power generation and CO<sub>2</sub> sequestration.**
- **Incremental cost of energy is anticipated to be less than 35% of the cost-of-electricity due to the on-going commercialization of the technology and high volume manufacturing.**